



Department of Public Works
Infrastructure Services Division

Ghassan Korban
Commissioner of Public Works

Preston D. Cole
Director of Operations

Jeffrey S. Polenske
City Engineer

August 10, 2015

Subject: Official Notice No. 124-1-2015

Lincoln Avenue Vehicle Storage Garage – HVAC System Replacement
3921 West Lincoln Avenue
Milwaukee, Wisconsin

For which bid will be received on
Tuesday, August 18, 2015

Addendum No. 1

- A. In regard to our advertisement for the Lincoln Avenue Vehicle Storage Garage – HVAC System Replacement, 3921 West Lincoln Avenue, Milwaukee, Wisconsin this attached Addendum No. 1 is issued to modify the original documents and is hereby made part of the proposal.
- B. Each bidder shall read the entire addendum. Proposals shall include all items included in this Addendum No. 1.

Very truly yours,

Paul R. Fredrich, Facilities Operations Manager
Bridges and Buildings



Official Notice No. 124-1-2015

Lincoln Avenue Vehicle Storage Garage – HVAC System Replacement
3921 West Lincoln Avenue
Milwaukee, Wisconsin

Addendum No. 1

IMMEDIATELY UPON RECEIPT OF THE ADDENDUM, PLEASE SIGN THIS RECEIPT AND
FAX BACK TO DPW-BRIDGES AND BUILDINGS SECTION AT (414) 286-5907 OR EMAIL
(dpitts@milwaukee.gov).

Company Name

Name

Date





HVAC ♦ Plumbing ♦ Fire Protection ♦ Electrical ♦ Commissioning

1 ADDENDUM NO. 1

2 ISSUE DATE: 08. 10.15

3
4 RE: Lincoln Avenue Vehicle Storage Garage HVAC Systems Replacement

5
6 R & D Project No. 215037.00

7
8
9 TO: Prospective Bidders

10
11 This addendum forms a part of the Contract Documents and modifies the original Contract Documents
12 dated [July 16th 2015] as noted below. Acknowledge receipt of this Addendum by inserting the number
13 and issue date of this addendum in the blank space provided on the Bid Form. Failure to do so may
14 subject the Bidder to disqualification.

15
16 This Addendum consists of [This Page] and the attached cover letter.

17
18
19 CHANGES TO SPECIFICATIONS (DIVISIONS 23):

20
21 1. Revised Mechanical Specifications section 23. 73.39 – Direct Gas Fired MAU - Part 2 Products 2.1
22 DIRECT GAS FIRED MAKE-UP AIR UNITS, to include the following:

- 23
24 O. Integration with existing (JCI) BAS:
25 1. Provide BACnet MS/TP integration card and /or control interface to BAS, coordinate
26 with temperature controls contractor.
27
28
29
30
31
32

END OF ADDENDUM

Ring & DuChateau Consulting Engineers
10101 Innovation Drive--Suite 200, Milwaukee, WI 53226
Phone 414.778.1700 / Fax 414.778.2360 / E-Mail r-d@ringdu.com